




CVKR SILENCING CHECK VALVE



Technical requirement

1. Flange dimension conforms to IN 2532;
2. Material conforms to GB/T 12225;
GB/T 12227;
GB/T 12229;
3. Test conforms to GB/T 13927;

Property Specification		
	PN	1.0
Test	Pressure test 1.5	Mpa
	Upper seal test	
Press	Seal test	
	Gas seal test	
	Max temp.	0~80
Service: water and other similar liquid		

8	Stem	2Cr13	
7	Guide	Copper alloy	
6	Spring	Stainless steel	
5	Spring gland	2Cr13	
4	Gland	25	
3	Disc	WCB	
2	Sealing ring	EPDM	
1	Body	HT200	
Item	Part name	Material	Note

1200	524	1455	1380	32-φ39
1000	432	1230	1160	28-φ36
900	368	1115	1050	28-φ33
800	356	1015	950	24-φ33
700	280	895	840	24-φ30
600	222	780	725	20-φ30
500	219	670	620	20-φ27
400	191	565	515	16-φ27
350	184	505	460	16-φ23
300	181	445	400	12-φ23
DN	L	PN1.0Mpa		
		D	D1	n-φd
Main dimension list (mm)				